PINE & FLYNN DEVELOPMENT COA LEVEL II

ARCHITECT

JRMA DESIGN STUDIO

175 SUMMIT CIRCLE SHELBURNE VERMONT 802 985 9363

WWW.JRMADESIGNSTUDIO.COM

CIVIL ENGINEERING

SUMMIT ENGINEERING 1233 Shelburne Road South Burlington, Vermont

658 - 5588

STRUCTURAL ENGINEERING

j.e BAKER ENGINEERING, PC 7 Cedar Glen North South Burlington

318 - 1080

GENERAL CONTRACTOR

WRIGHT AND MORRISSEY, INC 99 Swift Street South Burlington

863 - 4541

DRAWINGS

REFERENCE

R-1 VICINITY MAP

R-2 CONTEXT PHOTOS

R-3 **EXISTING DESIGN PRECEDENT**

DESIGN OBJECTIVES

D-1 **DESIGN OBJECTIVES**

CIVIL ENGINEERING

EXISTING CONDITIONS

PROPOSED SITE PLAN SP-1

D-1 SITE DETAILS

D-2 **EROSION CONTROLS**

ARCHITECTURE

DRAWINGS	PERMIT STAGE	CONSTRUCTION DRAWIN	GS
CONCEPTUAL	SKETCH / DISCRETIONARY	25 % COMPLETE	
SCHEMATIC	PRELIMINARY	50 % COMPLETE	
DESIGN DEVELOPMENT	FINAL	75 % ISSUE FOR BID	5
	ACT 250	100 % COMPLETE	

DEPARTMENT OF PLANNING & ZONING

DDAMMICO

PINE & FLYNN DEVELOPMENT | SKETCH PLAN REVIEW

PROJECT NAME PINE & FLYNN DEVELOPMENT PROJECT ADDRESS | 316 – 322 FLYNN AVENUE

TAX PARCEL NUMBER 057-4-066-000

OWNERS SIGNATURE

NAME OF APPLICANT MICHAEL F. ALVANOS C/O G & C PROPERTIES MAILING ADDRESS 90 SETH CIRCLE, WILLISTON, VERMONT 05495

TELEPHONE NUMBER 802 343 6789

E-MAILMICHAEL @ ALVANOSPMG.COM

LEAD ARCHITECT WILLIAM JOHN ROONEY | JRMA DESIGN STUDIO

TELEPHONE NUMBER 802 985 9363

DESCRIPTION

The project site is situated along the eastern side of Pine Street and along the northern part of Flynn Avenue at its respective corners. The site is currently occupied by three (3) separate structures. First, a commercial store and deli, a three (3) unit residential building and a garage that houses a recycling center for the store/deli.

The proposed development program includes the demolition of the existing store/deli and the garage that houses the recycling center. A new mixed use structure will be erected on site that will house a ground level commercial, replacing and reintroducing the store and adding new office space to the lower level. Above the commercial 2 levels of residential apartments will provide much needed housing to this area.

NOTEABLE IMPROVEMENTS

ENGLESBY STORMWATER IMPROVEMENTS

One of the goals of this project is the improvement of the Englesby Brook Storm Water Management system. Improvement on the land will allow all the storm water to be either infiltrated through improved landscaping, or, via an underground retention system that will house and treat all stormwater prior to discharge back into the ecosystem.

ENERGY EFFICENCY THROUGH MIXED-USE

Prior to submitting this project, Michael Alvanos and Eric Hoekstra, spearheaded a zoning change through the Burlington Planning Commission to provide the local residences improved zoning laws that would support mixed-use developments. Mixed-Use Development and infill design are cornerstones to improved energy efficiency.

UPDATED ARCHITECTURAL VENACULAR

The "South-End" of Burlington over the last 20 years has seen increased commercial development. With Dealer.Com, Burton Snowboards and Champlain College offering over 500 jobs, the demand to live close to where one works becomes a valuable asset to keeping these jobs local. The design of the building will adhere to the architectural vernacular created by these local businesses.








Stantec Preliminary Report
Pine & Flynn Development | JRMA Design Studio
June 2014

ITEM	VALUE	SOURCE
Existing (2003) PM Peak Hour Entering	Volume 1280	Champlain Parkway EIS Figure 3-3
Proposed Dwelling Units	9 New 3 Existing (12 Total)	JRMA Design Studio
PM Peak Hour Trips per Unit	0.62	ITE Trip Generation Land Use Code 220, Apartments
Expected Residential PM Peak Trips	10.54	
Net Proposed Commercial/Office Space (SF)	1130	JRMA Design Studio
PM Peak Hour Trips per KSF	1.49	ITE Trip Generation Land Use Code 710, General Office
Expected Commercial PM Peak Trips	4.47	
Total Expected PM Peak Trips	15.01	
Percentage of Trips Using Intersection		Stantec assumption (traffic oriented to Pine St-North and Flynn Ave-
PM Peak Trips Added to Intersection	8	East may not need to use intersection)
Percentage Change in Intersection Volumes	%9.0	



RECEIVED

APR 28 R-1

DEPARTMENT OF PLANNING & ZONING

2015



- 1. EXISTING DELI (PINE ST. DELI)
- 2. CHAMPLAIN SCHOOL
- 3. ST. ANTHONY'S CHURCH & OFFICE
- 4. HOWARD CENTER



















EXISTING DESIGN PRECEDENT

- 1. MALTEX BUILDING (PINE ST.) AIA AWARD RECIPIENT*
- 2. BURLINGTON ELECTRIC (PINE ST.)
- 3. BURTON SNOWBOARDS (INDUSTRIAL DR.)
- 4. BURLINGTON PUBLIC WORKS (PINE ST & LAKESIDE)
- 5. CHAMPLAIN COLLEGE (LAKESIDE)
- 6. FLYNN AVE. CO-OP (FLYNN AVE)





5.



NOTABLE DESIGN ELEMENTS

- 1. Use of Metal & Glass
- 2. Flat or Low Pitch Roof
- 3. Use of Masonry (Brick)
- 4. Integration of Landscape Elements
- 5. Large (over 20,000 S.F +/-) Buildings where the height is at or over 35'-0"





DESIGN OBJECTIVES

1. DESIGN A RELATIONSHIP BETWEEN THE SIDEWALK AND THE STREET

The Streetscape along Flynn Ave is characterized by the mature tree canopy that is consistent along most of Flynn Ave to the north and south sides all the way to its terminus at Oakledge Park. We see a typical sidewalk width of 5' - 0"

The Pine Street Streetscape, towards the South End, is characterized by mainly larger buildings with little vegitation that protects the pedestrian from the street. Fewer plantings and minimal setbacks to commercial spaces

The ability to wrap the landscape into the design will remain a high priority. Tree plantings along Pine Street & Flynn Ave should protect the building and pedestrians from weather and provide shade during summer seasons.





2. CREATE A VISUALY INTERESTING ELEVATION

The South End of Burlington, has been, and continues to be the location and heart of the Burlington Arts District. With the success of First Friday, and the annual Art Hop, the ability to support these events through visually interesting architecture become a main design goal. Moreover, Professional Design Firms, Engineering, Computer Science, Web-Site Design and Marketing firms all call the South End of Burlington Home. The Design must remain sensitive to the existing residential program yet also continue to strengthen the creative nature of the South End. A major component to this is how the West & South Elevation are treated along with the Material Selection of the Building.








3. SUPPORT A VARIETY OF MIXED-USE

The South End is a notable community that is truly mixed use. It location near the Burlington Bike Path, Schools, Cafes, Shopping Centers and major transportation routes requires the building to be designed with multiple programs to meet the needs of the community. Any other approach would fail to recognize its strategic position and miss a valuable opportunity for smart growth as listed in the Comprehensive Development Plan for Burlington.

Also, the Burlington Planning Commission supported a change of zoning for this property and others in the hopes of providing greater Mixed-Use potential to a valuable corner in Burlington Vermont.





ARCHITECT

JRMA design studio

PINE & FLYNN

316 FLYNN AVE (CORNER OF PINE & FLYNN BURLINGTON, VERMONT

OWNER

CIVIL ENGINEER




ue	Date	Issue	Dutu

Drawing Table EXISTING CONDITIONS PLAN

Project No.8163 Drawn By BEG Date 2/10/15 Scale 1"=20"

EC1



NOTES NO BASE LAYERS SHALL BE COMPACTED TO MIN. 95% STANDARD PROCTOR IN 6" LIFTS. ALL MATERIALS SHALL CONFORM TO YT. ADT STANDARD SPECIFICATIONS FOR CONSTRUCTION 2011 ED.


*SECTION TO BE USED WHERE RECLAIM IS NOT ADEQUATE

TYPICAL PAVEMENT SECTION

-PORTLAND CEMENT CONCRETE CURB SECTION 616.06. CONCRETE SHALL BE 3500 PSI © 28 DAYS IN 6' SECTIONS WITH EXPANSION JOINTS 20' O.C.. 1/4"PER FT BITUMINOUS CONCRETE &


BASE MATERIALS PER TYPICAL
PAVEMENT SECTION 1...0... — 12" GRAVEL (SUBSECTION 704.05, TABLE A, COARSE) USE 24" GRAVEL-SPECIAL SECTION WHEN SUBGRADE II >10% PASSING #200 SIEVE NOTE:
REFERENCED SPECIFICATION SECTIONS SHALL BE IN
CONFORMANCE WITH THE VERHONT AGENCY OF
TRANSPORTATION STANDARD SPECIFICATION FOR
CONSTRUCTION, CURRENT EDITION.

CURB AND PAVEMENT TYPICAL




NOTES.
THE CROSSING SHALL BE ARRANGED AS SHOWN SO THAT THE SEMER JOINTS ARE AS FAR AS POSSIBLE AND EQUIDISTANT FROM THE POINT OF INTERSECTION, PROVIDE PIPE FITTING RESTRAINTS AND BLOCKING AS NECESSARY.


WATER/SEWER CROSSING TYPICAL



SIDEWALK RAMP DETAIL




TYPICAL DUMPSTER PAD



CLASS II MATERIAL (SAND)
SHALL COMPLY MITH THE FOLLOWING GRADATION REQUIREMENTS:
U.S. SIEVE SIZE
PERCENT PASSING
NO. 4
100


TRENCH TYPICAL



NOTE: TAPPING SLEEVE SHALL BE OF THE SPLIT SLEEVE DESIGN CONSTRUCTED WITH TWO SOLID HALF-SLEEVES BOLTED TOOETHER. SLEEVES SHALL BE CONSTRUCTED OF CAST IRON OR DUCTULE IRON. SHALL HAVE A WORKING PRESSING OF AT LEAST OF 150 PS, AND SHALL HAVE MECHANICAL JOHN ENDS WITH END AND SIDE GASKET SEALS. SLEEVES SHALL BE PROVIDED WITH A 3/4" NOT TEST PLUG. ALL BOLTS AND NUTS FOR DECHANICAL LOWITS AND THEPPING SLEEVES SHALL CONFORM TO ANS/AWMA CITI/AZI.11 AND BE CLEAN AND COATED WITH A RUST-RESISTANT LUBRICANT WITH THER SLIFFACES FREE OF GASECTIONALE PROTRUSIONS. ALL BOLTS AND NUTS OF THE TOWN SHALL BOLTS AND SHALL BE BRUSH COATED WITH BUTTAND SHALL BE BRUSH COATED MITH BUTWASTIC COLD—APPLIED MATERIAL.


TAPPING VALVES SHALL HAVE A MINIMUM WORKING PRESSURE OF 150 PSI. THE INLET FLANGES SHALL BE CLASS 125 CONFORMING TO ANSI B16.1 OF ANSI/AWWA C110/A21.10 AND OUTLET CONNECTION SHALL BE STANDARDIZED MECHANICAL JOINT.

TAPPING SLEEVE AND VALVE




NOTE:
CONSTRUCT EXPANSION & CONTRACTION JOINTS
EVERY 20' WITH DUMMY JOINTS EVERY 5'.

SIDEWALK TYPICAL



NOIES: ACAID PRECAST CONCRETE PRODUCTS, INC. PRECAST REINFORCED CONCRETE CATCH BASIN, OR EQUAL. H20 (ADAIMC CAPABILITY IS REQUIRED, CONCRETE SHALL BE 4,000 PS MINIMUM AT 28 DAYS. FRAME & GRATE SHALL BE LEBARON NO. 248–2, OR EQUAL.

TYPICAL CATCH BASIN



5'-0"

8'-0" FOR VAN ACCESSIBLE

APR 2 8 2015

-SIGNS SHOWING SYMBOL OF-ACCESSIBILITY, TYP.

- 1.) BITUMINOUS CONCRETE RAMP SHALL MEET TOP OF SIDEWALK CURB.
- 2.) HANDICAP SYMBOL SHALL BE CENTERED IN PARKING STALLS.
- 3.) HANDICAP RAMP SHALL BE STRIPED AND TEXTURED IN CONFORMANCE WITH VIRANS STD C-3A & C3B
 4.) HANDICAP RAMP SLOPE SHALL NOT EXCEED 8.3%

HANDICAP PAVEMENT MARKING DETAIL

WATER LINE INSTALLATION AND TESTING

- BEFORE CONSTRUCTION OF ANY UTILITIES OR IMPROVEMENTS, THE CONTRACTOR SHALL MOTHEY THE MUNICIPAL WATER DEPARTMENT IN WRITING, OF THEIR INTERNIT TO PROCEED AND SHALL ARRANCE FOR A MEETING MITH THE DEPT, THE ENGINEER, AND THE CONTRACTOR TO DISCUSS THE PROJECT.
- ALL WATER MAINS, FITTINGS, APPURTENANCES, AND OTHER MATERIALS
 AND CONSTRUCTION SHALL CONFORM TO ALL APPUCABLE AWM, STATE
 AND TOWN CODES, STANDARDS, AND REGULATIONS. IN CASE OF
 COVINEIT BETWEEN THESE CONSTRUCTION DETAILS AND
 SPECIFICATIONS, AND A CODE OR REGULATION, THE DECISION OF
 THE VERMONT DEPT. OF HEALTH OR THE MUNICIPAL WATER DEPARTMENT
 SHALL BE BRIDNING.
- CONNECTION TO AN EXISTING WATER MAIN SHALL BE DONE BY OR UNDER THE SUPERINSON OF AND WITH THE APPROVAL OF THE MUNICIPAL WATER CHERACTERIST. IT IS THE CONTRACTORS RESPONSIBILITY TO SECURE ALL NECESSARY PERMITS AND PERMISSION TO MAKE THE CONNECTION AND TO COORDINATE ALL PARTIES INVOLVED IN THE PROCESS. THE MUNICIPAL WATER DEPARTMENT AND EXCINER SHALL BE NOTIFIED AT LEAST FORTY-EIGHT (48) HOURS IN ADVANCE OF THE INTENDED CONNECTION TIME.
- 5. ALL PUBLIC AND PRIVATE WATER MAINS: 1) 4" OR GREATER SHALL BE DUCTILE TROM, MINIMUM CLASS 52, DOUBLE CEMENT LINED, MECHANICAL OR PUSH ON JOINT PIPE. 2) LESS THAN 4" IN DIAMETER SHALL BE TYPE K COPPER.
- ALL WATER LINE FITTINGS SHALL BE DUCTILE IRON, (AWWA C-110) CEMENT-LINED. WATER LINES LESS THAN 4" IN DIAMETER FITTINGS (OTHER THAN VALVES), SHALL BE BRASS.
- 7. ALL BURIED GATE VALVES SHALL CONFORM TO AWMA C-500 OR C-509
 AND BE 150 LB. IRON BOOY, BRONZE MOUNTED
 RESULENT MEDGE TYPE. ALL GATE VALVES
 SHALL HAVE ADJUSTABLE IRON VALVE BOXES EXTENDING TO THE
 FINISHED GRADE (SEE TYPICAL DETAILS)
- FINISHED GRADE (SEE TIPICAL DETAILS).

 ALL WATER LINES AND APPURTENANCES SHALL BE PRESSURE AND LEAK TESTED BEFORE BEING PLACED INTO SEPMOE, ACCORDING TO ANWA STANDARD C-551. THE TEST PRESSURE SHALL BE 200 PS (4/- 9F3), MESSURED AT OR MEAR THE HIGH POINT IN THE PROPERTY OF THE PROPERTY OF THE HIGH POINT IN THE PROPERTY OF THE PROPERTY OF THE HIGH POINT IN THE PROPERTY OF THE WAND THE EXPOSED SHALL BE GIVEN AT LEAST FORTY-CHIGHT (48) HOURS NOTICE BEFORE THE TEST IS TO BE CONDUCTED, AND THE MUNICIPAL WATER DEPARTMENT PERSONNEL SHALL WITNESS THE TEST ALLOWARDS LEMAGE SHALL BE COMPUTED BY ONE OF THE FOLLOWING FORWARDS. THE CHOCK TO BE MADE BY THE MUNICIPAL WATER DEPARTMENT. HOUSER OF GALS.

 YELLOWING FOR MARKET DEPARTMENT. HOUSER OF GALS.

 YELLOW THE FOLLOWING FORWARDS. THE CHOCK TO BE MADE BY THE MUNICIPAL WATER DEPARTMENT.

 YELLOW THE FOLLOWING FORWARDS. THE CHOCK TO BE MADE BY THE MUNICIPAL WATER DEPARTMENT.

 YELLOW THE FOLLOWING FORWARDS. THE CHOCK TO BE MADE BY THE MUNICIPAL WATER DEPARTMENT.

 YELLOW THE FOLLOWING FORWARDS. THE STANDARD OF THE FOLLOW THE STANDARD OF THE FOLLOW THE STANDARD OF THE TEST OF
- CERTIFY THE RESULTS TO THE MUNICIPAL WATER DEPARTMENT.

 9. ALL WATER LINES SHALL BE DISINFECTED IN ACCORDANCE WITH AWAY.

 AWAY.

 6-01, OR AS DIRECTED BY THE MUNICIPAL WATER DEPARTMENT BEFORE BEING PUT INTO SERVICE. THE CONTRACTOR SHALL INSTALL A 1" DIMETER TAP IN THE WATER MUNIFOR CHOOMIE INJECTION. THE TAP SHALL BE LOCATED AS DIRECTED BY THE MUNICIPAL WATER DEPARTMENT. DISINFECTION SHALL BE ACCOMPLISHED BY INTRODUCING A CONCENTRATION OF SO PARTS PER MILLION (PMJ) OF AVAILABLE CHOOMIE INTO A REPARTMENT FOR MICHAEL STATE OF THE PERSON(S) PROSPECTION OF A THE WATER HAND FOR STATE OF THE PERSON(S) RESPONSIBLE FOR DISINFECTION SHALL REPORT IN WRITING, TO THE MUNICIPAL WATER DEPARTMENT AND VERMONT DEPT. OF HEALTH, THAT THIS DISINFECTION PROCEDURE WAS FOLLOWED AND THE REPORTMED MINIOUR RESULTS WERE OBTAINED. ACTUAL SAMPLING SHALL BE PERFORMED BY THE MUNICIPAL WATER DEPARTMENT AND VERMONT DEPT. OF HEALTH, THAT THIS DISINFECTION PROCEDURE WAS FOLLOWED AND THE RECOVER MINIOUR RESULTS WERE OBTAINED. ACTUAL SAMPLING SHALL BE PERFORMED BY THE MUNICIPAL WATER DEPARTMENT, THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL SAMPLING AND ANALYSIS COSTS.

SEWER CONSTRUCTION AND TESTING NOTES

- All sewer pipe shall be PVC SDR 35 gravity sewer pipe manufactured in confor with ASTM D 3034 (4" to 16") and installed in conformance with ASTM recor practice D2321. Joints, fittings, and accessories shall also conform to the appropriate specifications for PVC pipe size.
- 2. Instell sewer pipe in conformance with the engineering plans and specifications and manufacturer's recommendations. PVC gravity sewer pipe shall be furnished in the longest nominal lengths available from the manufacturer. The pining procedure shall conform with the manufacturer's recommendations as outlined. Gastels used in joining PVC sewer pipe shall conform to the requirements of ASIM F477.
- J. Pipe shall be laid accurately to line and grade. Bedding in earth shall be a minimum of 6° below the outside of the pipe barrel. Bedding shall extend up to the spring line. Material around and to a height of 1° above the pipe shall be sand bockfilled. Bedding and sand cushion shall be compacted by mechanical tamping in 1 foot lifts.
- 4. Pipe shall be lold with the spigot ends pointing in the direction of flow, and on a dry bedding. Completed pipelines shall be free from offsets or deviations from line and grade when examined with lights or mirrors. Visible teaks, broken pipes, etc., shall be repoiled. Pipe shall be plugged with a water tight plug at hight or when shall be repoiled. Pipe shall be plugged with a water tight plug at hight or when shall be provided by the provided provided from the transit. The Controctor shall clean all soil deposits and other delvis from severs at the completion of the wark.
- Any service connections shall be 4 inch SDR 35 PVC and shall be constructed in a location to be determined by the Engineer. The service connection shall be 6' below existing grade unless otherwise indicated on the plans or as directed by the Engineer. The end shall be located by two intersecting tiles by the Engineer before being backfilled and shall be marked with a 2" by 4" board coated with preservative extending from the connection invert to 6" below existing grade and with metal tape or a metal marker suitable for detection with a metal detector.
- Pre-cast bases shall be placed on a 6" layer of compacted bedding material. The excavation shall be properly dewotered while placing bedding material and setting the base or pouring concrete. Water stops shall be used at the horizontal joint of poured-in-place manholes.

*Borrel sections and cones of the appropriate combination of heights shall then be placed, using manufacturer's recommended procedures for sealing the horizontal plints, and as shown on the typical sections.

leakage test shall be made on all sanitary manholes prior to building manhole

The frame and cover shall be placed on the top to prevent occidental entry of unauthorized persons, children, animals, etc., until the Contractor is ready to make final adjustment to grade.

- Manholes shall be backfilled evenly in layers with suitable backfill material and compacted to achieve 95% maximum density.
- DEPARTMENT OF Connections to existing memboles shall be made so as not to damage the structure. The openings shall be mortared full and waterlight after the new pipe is installed. The inverts shall be modified as directed to accommodate flow from the new pipe.

JRMA design studio JRMA DESIGN STUDIO LLP 175 SUMMIT CIRCLE SHELBURNE VERMONT

ARCHITECT

PINE & FLYNN DEVELOPMENT

LOCATION

316 FLYNN AVE (CORNER OF PINE & FLYNN BURLINGTON, VERMONT

OWNER

G & C PROPERTIES BURLINGTON, VERMONT TEL: 802 343 6789

CONTRACTOR

CIVIL ENGINEER

SUMMIT ENGINEERING, INC 1233 Shelburne Road C2 South Burlington, VT 05403

STAMP



ksue	Date	Issue	Dute

SITE DETAILS


Project No.8163 Drawn By BEG Date 2/10/15 Scale N.T.S.

Drawing No.

D1

- PREPARE SOIL BEFORE INSTALLING ROLLED EROSON CONTROL PRODUCT (RECP's), INCLUDING ANY NECESSARY APPLICATION OF LINE, FERTILIZER, AND SEED. NOTE: WHEN USING CELL-O-SEED DO NOT SEED PREPARED AREA. CELL-O-O-SEED MUST BE INSTALLED WITH PAPER SDE DOWN.
- BEGIN AT THE TOP OF SLOPE BY ANCHORING THE RECP's IN A 6" (15 CM) DEEP X 6" (15 CM) WIDE TRENCH WITH APPROXIMATELY 12" (30 CM) OF RECP's EXTENDED BETOND THE UP-SLOPE PORTION OF THE TRENCH. ANCHOR RECP's WITH A ROW OF STAPLES/STAVES APPROXIMATELY 12" (30 CM) OF RECP's APART IN THE BOTTOM OF THE TRENCH AROUTED. ANO FELT THE TRENCH AFTER STEAMUR. APPLY SEED TO COMPACTED AND FOLD REMAINING 12" (30 CM) PORTION OF RECP's APART IN THE BOTTOM OF RECP's APART SEED AND FOLD REMAINING 12" (30 CM) PORTION OF RECP's AND COMPACTED SOLUTION OF RECP'S APART AROUTED THE MOTHOR FOLLOWS.
- ROLL THE RECO'S (A.) DOWN OR (B.) HORZONTALLY ACROSS THE SLOPE, RECO'S WILL UNROLL WITH APPROPRIATE SIDE ACAINST THE SOIL SURFACE, ALL MUST BE SECURELY, FASTERED TO SOIL SURFACE BY PLACING STAPLES/STAKES IN APPROPRIATE LOCATIONS AS SHOWN IN THE STAPLE PATTERN QUIDLINGN THE DOT SYSTEM STAPLES/STAKES SHOULD BE PLACED THROUGH EACH OF THE COLORED DOTS CORRESPOND TO THE PROPRIATE STAPLE
- THE EDGES OF PARALLEL RECP'S MUST BE STAPLED WITH APPROXIMATELY 2" 5" (5CM 12.5CM) OVERLAP DEPENDING ON RECP'S TYPE.
- CONSCUTIVE RECP'S SPLICED DOWN THE SLOPE MUST BE PLACED END OVER END (SHINGLE STYLE) WITH AN APPROXIMATE 3" (7.5 CM) OVERLAP. STAPLE THROUGH OVERLAPPED AREA, APPROXIMATELY 12" (30 CM) APART ENTIRE RECP'S EDITH.

NOTE: IN LOOSE SOIL CONDITIONS, THE USE OF STAPLE OR STAKE LENGTHS GREATER THAN 6" (15 ON) MAY BE NECESSARY TO PROPERLY SECURE THE RECP'S.



- 1. PREPARE SOIL BEFORE INSTALLING ROLLED EROSION CONTROL PRODUCTS (RECP*a), INCLUDING ANY NECESSARY APPLICATION OF LINE, FERTILIZER, AND SEED, NOTE: WHEN USING CELL—O-SEED DOWN.

 2. BEGIN AT THE TOP OF THE CHANNEL BY ANOHORING THE RECP*a N. A. F. (1). SO AND THE CHANNEL BY ANOHORING THE RECP*a N. A. F. (1). SO AND THE CHANNEL BY ANOHORING THE RECP*a N. A. F. (1). SO AND THE CHANNEL BY A STATE OF THE TRENCH. ANOHORING THE RECP*a WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" (30 CL) APART IN THE BOTTON OF THE TRENCH. BACKFILL AND COMPACTED THE TRENCH ATTER STAPLING, APPLY SEED TO COMPACTED SOIL AND FOLD REAMHING 12" (30 CL) PORTION OF RECP*a BACK OVER SEED AND COMPACTED SOIL. SECURE RECP*a OVER COMPACTED SOIL WITH A ROW OF STAPLES/STAKES SPACED APPROXIMATELY 12" (30 CM)


 ACROSS THE WIDTH OF THE RECP*a.
- 3. ROLL CEMTER RECP'S IN DIRECTION OF WATER FLOW IN BOTTOM OF CHANNEL. RECP'S WILL UNROLL WITH APPROPRIATE SDE AGAINST THE SOIL SURFACE, RECP'S MUST BE SECURELY FASTENDE TO SOIL SURFACE BY PUACHO STAPLES/STAVES IN APPROPRIATE LOCATIONS AS SHOWN IN THE STAPLE PATTERN GUI WHEN USING THE DOT STSTEM, STAPLES/STAXES SHOULD BE PLACED THROUGH EACH OF THE COLORED DOTS CORRESPONDING TO THE APPROPRIATE STAP
- 4. PLACE CONSECUTIVE RECP's END OVER END (SHINGE STILE) WITH A 4" 6" (10 CM -15 CM) OVERLAP. USE A DOUBLE ROW OF STAPLES STAGGERED 4" (10 CM) APART AND 4" (10 CM) ON EXTREST TO SECURE RECP's.
- 5. FULL LENGTH EDGE OF RECP's AT TOP OF SIDE SLOPES MUST BE ANCHORED WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" (30 CM) APART IN A 6" (15 CM) DEEP X 6" (15 CM) WIDE TRENCH. BACKFILL AND COMPACT THE TRENCH AFTER STAPLING.
- E. ADJUCENT RECP's MUST BE OVERLAPPED APPROXIMATELY 2" 5" (5 CM 12.5 CM) (DEPROINING ON RECP's TYPE) AND STAPLED.

 7. IN HIGH FLOW CHANNEL, APPLICATIONS, A STAPLE CHECK SLOT IS RECOMMENDED AT 30 TO 40 FOOT (9 M 12 M) INTERVALS, USE A DOUBLE ROW OF STAPLES STAGGERED 4" (10 CM) APART AND 4" (10 CM) APART AND 4" (10 CM) APART AND 4" (10 CM) OR CENTER OVER ENTIRE WORTH OF THE TANNEL.
- 8. THE TERMINAL END OF THE RECP's MUST BE ANCHORED WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" (30 CM) APART IN A 6" (15 CM) DEEP X 6" (15 CM) MIDE TRENCH, BACKFILL AND COMPACT THE TRENCH AFTER STAPLING.


NOTE:

* IN LOOSE SOIL CONDITIONS, THE USE OF STAPLE OR STAKE LENGTHS GREATER THAN 6" (15 CM) MAY BE NECESSARY TO PROPERLY ANCHOR THE RECP'S.

EROSION CONTROL MATTING - CHANNEL INSTALLATION




AS PER PLAN - 50' MINIMUM 40E0E0E0E0E0E0E0E0E0E0E0E0



PLAN


1. STONE SHALL BE 1.5 TO 4 INCHES WITH A MINIMUM THIOCHESS OF 8 INCHES. 2. LENGTH, WIDTH AND RETURN RADIUSES SHALL BE AS SHOWN ON THE APPLICABLE CONSTRUCTION STABILIZATION PLAN.

5. CONSTRUCT STABILIZED APRON AROUND BUILDING AS SHOWN ON THE PLAN, AND WITH THE PROFILE SHOWN ABOVE. STABILIZED CONTRUCTION ENTRANCE NOT TO SCALE



- THE WIRE MESH SHALL BE COVERED WITH CLEAN COARSE AGGREGATE SUCH AS CRUSHED STONE FOR A MINIMUM DEPTH OF 12 INCHES. CRUSHED STONE SHALL BE BEDDING STONE FOR SEWERS (ASTM STONE SIZE NO. 67). SEE SPECIFICATIONS.
- THE COARSE AGGREGATE SHALL EXTEND AT LEAST 18 INCHES BEYOND ALL SIDES OF THE CATCH BASIN/DRAIN OPENING.
- THIS SEDIMENTATION CONTROL SHALL BE UTILIZED AT ALL CATCH BASINS THAT WILL RECEIVE RUNOFF FROM DISTURBED AREAS.
- GEOTEXTILE BAG PRODUCTS DESIGNED FOR EROSION CONTROL AT CATCHBASINS ARE ACCEPTABLE ALTERNATIVES PROVIDED THEY ARE INSTALLED AND MAINTAINED PER MANUFACTURERS RECOMMENDATIONS.
- SILT FENCING PROPERLY INSTALLED AND MAINTAIN AROUND CATCH BASINS IN GRASS AREAS IS AN ACCEPTABLE ALTERNATIVE.

SEDIMENTATION CONTROL AT CATCH BASIN



TYPE I STONE OF

FILTER FABRIC STAPLED TO STAKE, TO BE MIRAFI 100X OR APPROVED EQUAL

EXISTING GRADE

DECIDUOUS TREE PLANTING DETAIL

andscaping Notes:

Landscape architect shall be notified to inspect proposed locations of plant material and condition of plant materials when delivered to site prior to installation.

All plant material is to conform to the requirements of ANSI 250.1 "American Standard for Nursery Stock" for quality, size, genus, species and variety shown on the planting plan, Landscape contractor shall be responsible for identifying locations of underground utilities prior to excavation for planting.

EROSION PREVENTION AND SEDIMENT CONTROL STABILIZATION NOTES:

1. MULCH SHALL BE APPLIED TO ALL DISTURBED AREAS AT 2 TONS PER ACRE, MULCH SHALL CONSIST OF AIR-DRIED HAY OR STRAW FREE OF SEEDS AND COARSE MATERIALS.

2. TOPSOIL PILES SHALL BE MULCHED AND RINGED WITH SILT FENCE

3. DISTURBED SOILS TO BE STABLED AS FOLLOWS:

CHANNEL SLOPE 1% TO 5% > 5%

SIDE SLOPES

- CONSTRUCTION FENCING 2' INSIDE SILT FENCE

0 0

NOTES.

INSTALL SUT FENCES AT TOES OF UNPROTECTED SLOPES AND AS PARALLEL TO CONTOURS AS POSSIBLE CURNE THE ENDS OF THE FENCE UP INTO THE FENCE OF THE FENCE OF THE FENCE OF THE FENCE OF THE FENCE CONTRACTOR SHALL INSTALL SUT FENCES AT THE TOE OF ALL FILLED OR UNPROTECTED SLOPES CREATED DURING CONSTRUCTION. NOT INCCESSARILY REFLECTED ON FINAL PLANS, SUT FENCES ARE TO BE AMANTALINED UNTIL SLOPES ARE STABILIZED, AND REMAIN THE PROPERTY OF THE CONTRACTOR.

SILT/CONSTRUCTION FENCE EROSION CONTROL TYPICAL

AS SPECIFIED

TYPICAL CROSS-SECTION

DUTLET SIDE & APRON

PLAN VIEW

LEVEL SPREADER DETAIL

CEOTEXTILE FAR

0

4. LIME MAY BE APPLIED TO ACHIEVE SOIL PH OF 6.5 FOR AREAS TO BE SEEDED.

6. LIME AND FERTILIZER SHALL BE MIXED THOROUGHLY INTO THE SEEDBED DURING SOIL PREPARATION.

7. GRASSED CHANNELS SHALL HAVE A MIN. OF 4" OF TOPSOIL PRIOR TO SEEDING. 8. DISTURBED SOILS SHALL BE SEEDED ACCORDING TO THE FOLLOWING TABLE:

APRIL 15 - SEPT. 15: RYEGRASS (ANNUAL OR PERENNIAL: 20 LBS/ACRE)
SEPT. 15 - APRIL 15: WINTER RYE (120 LBS/ACRE)

CHOOSE FROM:	VARIETY	LBSJACRE	LBSJ1000 SQ. FT
BIRDSFOOT TREFOIL OR	EMPIRE/PARDEE	5*	0.1
COMMON WHITE CLOVER PLUS	COMMON	8	0.2
TALL FESCUE PLUS	KY-31/REBEL	10	0.25
REDTOP OR	COMMON	2	0.05
RYEGRASS (PERENNIAL)	PENNFINE/LINN	5	0.1

LIMIT-OF-DISTURBANCE CORDON CONSTRUCTION SPECIFICATIONS

SAID FENCE SHALL BE SUPPORTED BY STEEL 'U' OR 'T' TYPE POSTS PLACED AT MAXIMUM 18-FOOT INTERVALS.

FENCE SHALL BE WIRE OR "ZIP" TIED TO THE SUPPORT POSTS.

EROSION PREVENTION AND SEDIMENT CONTROL CONSTRUCTION NOTES:

NEW LOT OWNERS/CONTRACTORS MUST COMPLY WITH THE EROSION PREVENTION AND SEDMENT CONTROL STANDARDS OF THE CITY OF BURLINGTON.

2. ALL TEMPORARY EROSION AND SEDIMENT CONTROL MEASURES MUST BE REMOVED WITHIN 30 DAYS AFTER FINAL SITE STABILIZATION OR AFTER TEMPORARY MEASURES ARE NO LONGER NEEDED, UNLESS OTHERWISE AUTHORIZED. 3. ALL AREAS MUST MAVE TEMPORARY OR PERMANENT STABILIZATION WITHIN 14 DAYS OF INITIAL DISTURBANCS. AFTER THIS THE ANY DISTURBANCS IN THE AREAS MINUST BE STABILIZED AT THE END OF EACH WORK DAY. THE FOLLOWING EXCEPTIONS APPLY.

STABILIZATION IS NOT REQUIRED IF WORK IS TO CONTINUE IN THE AREA WITHIN THE NEXT 24 HOURS AND THERE IS NO PRECIPITATION FORECAST WITHIN THE NEXT 24 HOURS.

STABILIZATION IS NOT REQUIRED IF THE WORK IS OCCURRING IN A SELF-CONTAINED EXCAVATION (I.E. NO QUILET) WITH A DEPTH OF 2 FEET OR GREATER (E.G. HOUSE FOUNDATION CREATER) UTILITY THE PROPERTY OF THE PROPERTY

4. ALL EROSION CONTROL NEASURES MUS BE INSPECTED AT A FREQUENCY OF EVERY 7 DAYS OR WITHIN 24 HOURS OF A PRECIPITATION EVENT CAUSING RUNOFF TO LEAVE CONSTRUCTION SITE, AND REPLACED OR REPAIRED AS NECESSARES.

EROSION CONTROL SEQUENCING

- DELINEATE THE AREA TO BE DISTURBED WITH LIMIT OF DISTURBANCE CORDON, SLT FENCE OR CONSTRUCTION FENCING AS APPROPRIATE.

CLOVER PER ACRE.

3. INSTALL TEMPORARY AND PERMANENT EROSION CONTROL FEATURES AS APPROPRIATE AND AS DESCRIBED IN THESE DETAILS.

WINTER CONSTRUCTION EROSION CONTROL MEASURES

ADDITIONAL EROSION PREVENTION AND SEDIMENT CONTROL MEASURES MUST BE IMPLEMENTED DURING THE WINTER CONSTRUCTION SEASON IF EARTH DISTURBANCE IS PLANNED DURING THIS TIME (OCTOBER 15TH) TO APPRIL 15TH). CONTRACTOR/LANDOWNER SHALL READ AND UNDERSTAND THE FOLLOWING

NON-VEGETATIVE PROTECTION MUST BE INSTALLED AFTER SEPTEMBER 15TH TO BARE SOILS INCLUDING EROSION CONTROL BLANKETS AND/OR HEAVY MULCH LAYER.

9. SILT FENCE AND OTHER PRACTICES WUST BE INSTALLED AHEAD OF FROZEN GROUND. 10. DESTURBED SOLS MUST BE STABLIZED AT THE EARL OF FACH MORE DAY, UNLESS NO PRECONTAINED. FORECAST WINN 24 HOURS AND MORK MLL RESULE WINN 24 HOUSER IN THE SAME DISTURBED AND AREAS THAT COLLECT AND RETAIN RUNGEF SUCH AS HOUSE FOUNDATIONS AND UNDUTY TREMOMES DAILY STABLIZATION IS NOT REQUIRED.

11. PRIOR TO STABILIZATION SHOW AND ICE SHALL BE REMOVED TO LESS THAN 1 INCH THICKNESS 12. USE STONE TO STABILIZE AREAS SUCH AS THE PERIMETER OF BUILDINGS UNDER CONSTRUCTION OF WHERE CONSTRUCTION VEHICULAR TRAFFIC IS ANTICIPATED. ARCHITECT

JRMA design studio

JRMA DESIGN STUDIO LLP 175 SUMMIT CIRCLE SHELBURNE VERMONT



PINE & FLYNN

LOCATION

316 FLYNN AVE (CORNER OF PINE & FLYNN BURLINGTON, VERMONT

OWNER

G & C PROPERTIES BURLINGTON, VERMONT TEL: 802 343 6789

CONTRACTOR

CIVIL ENGINEER

1233 Shelburne Road C2 South Burlington, VT 05403 (802) 858-5588

STAMP




FROSION CONTROL AND LANDSCAPINGDETAILS

Project No. 8163 Drawn By BEG Date 4/8/15 Scale N.T.S.

D2





(IN FEET) 1 inch = 20 ft

STORMWATER SYSTEM MAINTENANCE REQUIREMENTS

PROJECT DESCRIPTION

EXISTING CONDITIONS

The site runoff from the existing site runs to Englesby Brook via sheet flow, gutter flow, a cotch basin in Flynn Avenue and the Outlet drainage pipe in Pine Street. The site has no collection system with all the runoff exiting the site via sheet flow and overland flow. The majority of the site is covered by poved parking and rooftaps.

STORMWATER TREATMENT AND DRAINAGE CONSIDERATIONS -

The proposed starmwater treatment methods are the result of space limitations and the poor infiltration properties of the underlying soils. The inclusion of cotch basins and roof drain systems create a concentration of runoff to a new culvert to Englesby Brook. The installation of a Flow Attenuator/Sedimentation Tank prior to the final discharge is the most efficient method of Improving the runoff characteristics of the site. Improvious portions of the site will continue drain to the adjacent street systems and runoff directly to Englesby Brook.


Site Runoff will continue to enter the City of Burlington Municipal Stormwater system and the adjacent brook (Englesby) via overland flow, gutter flow, on-site and municipal catch basins storm pipes and a new treatment structure. The overall impervious area of the site will be reduced by approximately 2,200 sf with 9,000 sf of the new roof and poved surfaces being routed through the treatment tank.

The resulting stormwater design, including the Flow Reducer Tank, based on a TR-55 runoff model, will result in a reduction of the peak design flows for the 1, 2, 10, 25 and 100-year, 24-hour design storms as specified in the table included on the design plans and stormwater management details. Existing Impervious Lot Coverage

Tatal Lot 25,424 s.f. 0.61 acre 100%
Paved Area 14,697 s.f. 0.34 acre 55.6%

Building Area	4,742 s.f.	0.11 ocre	18,0%
Total Coverage	19,439 s.f.	0.45 ccre	73.6%
		ous Lot Cover	age
Total Lat	26,424 s.f.	0.61 ocre	100%
Paved Area	11,101 s.f.	0.25 acre	42.0%
Building Area	6,119 s.f.	0,14 acre	23.2%
Total Coverage	17,220 s.f.	0,40 ocre	65.2%
Effective Impervious	17.220 s.f.	0.40 ocre	65.2%
New Impervious			

Impervio	us Surface Mar	nagement
Standard	Net New Impervious	Redeveloped/Existing
Water Quality	0 s.f.	13,373 s.f.
Runoff Reduction	0 s.f.	13,373 s.f.
Q1 Peak Control	0 s.f.	13,373 s.f.
Q10 Peak Control	0 s.f.	13,373 s.f.



BIORETENTION SWALE DETAIL


- Void Rotio= 0.4
 Vertical Permeability of Porous Media = 10 Min/Inch

	Max Q	For 1"							
•	Storage	Volum	ie:						C.F./L
				4	Wide	Swale	-	40	C.F./L

Design Storm	Q-Pre Development	Q-Improvement Goal	Q-Post Developmen
WQ Storm	0.61 c.f.s.	0.49 c.f.s.	0.18 c.f.s.
Chit. 1yr-24hr	1,49 c.f.s.	0.75 c.f.s.	0.55 c.f.s.
Chit. 2yr-24hr	1.67 c.f.s.	0.90 c.f.s.	0.61 c.f.s.
Chit. 10yr-24hr	2.46 c.f.s.	1.63 c.f.s.	0.86 c.f.s.
Chit. 25yr-24hr	3.26 c.f.s.	2.42 c.f.s.	1.10 c.f.s
Chit. 100yr-24hr	4.25 c.f.s.	341 c.f.s	1.39 c.f.s.

Note: WQ flows based on colculations to maintain the minimum WQ Volume of 0.2"


Q-Improvement Goal models the site as if half the existing impervious is returned to natural condition.



Q-in / Q-out Of Treatment Tank

Storm Q-in Q-out WQ Storm 0.25 c.f.s 0.24 c.f.s. Chit. 1yr-24hr 0.64 c.f.s. 0.58 c.f.s.

Chit. 2yr-24hr 0.71 c.f.s. 0.63 c.f.s. Chit. 10yr-24hr 1.00 c.f.s. 0.85 c.f.s. Chit. 25yr-24hr 1.28 c.f.s. 1.05 c.f.s. Chit. 100yr-24hr | 1.63 c.f.s. | 1.55 c.f.s.




FLOW REDUCER TANK DETAIL

HEAVY DUTY 2500 GALLON TANK MODIFIED AS SHOWN. CAMP PRECAST OR EQUAL.

ARCHITECT

JRMA design studio

JRMA DESIGN STUDIO LLP 175 SUMMIT CIRCLE SHELBURNE VERMONT



PINE & FLYNN DEVELOPMENT

LOCATION

316 FLYNN AVE (CORNER OF PINE & FLYNN BURLINGTON, VERMONT

OWNER

G & C PROPERTIES BURLINGTON, VERMONT TEL: 802 343 6789

CONTRACTOR

CIVIL ENGINEER

1233 Shelburne Rood C2 South Burlington, VT 05403 (802) 656-5568

STAMP




Issue	Date Issue	
-		
-		
Project		

PLAN AND DETAILS


Project No. 8163 Drawn By BEGDFH Date 4/8/15 Scale N.T.S.

D3

COAL








<u>Plan View</u> Scale - 1" = 10'

Luminaire Symbol	Label	Quantity	Manufactur er	Catalog Number	Description	Lamp	Number	Filename	Lumens Per Lamp	Light Loss Factor	Wattage
	Α	3	Lithonia Lighting	DSX0 LED 40C 530 50K T4M MVOLT HS	DSX0 LED WITH (2) 20 LED LIGHT ENGINE, TYPE T4M OPTIC, 5000K, @ 530mA WITH HOUSE SIDE SHIELD	LED	1	DSX0_LED_4 0C_530_50K _T4M_MVOL T_HS.ies	5426.219	1	68
	В	1	Lithonia Lighting	DSX0 LED 20C 530 30K T2M MVOLT	DSX0 LED WITH (1) 20 LED LIGHT ENGINE, TYPE T2M OPTIC, 3000K, @ 530mA	LED	1	DSX0_LED_2 0C_530_30K _T2M_MVOL T.ies	2901.443	1	35

Statistics											
Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min	Avg/Max				
Driveway Flynn Street	+	0.9 fc	1.9 fc	0.0 fc	N/A	N/A	0.5:1				
Driveway Pine Street	+	0.2 fc	0.3 fc	0.2 fc	1.5:1	1.0:1	0.7:1				
Dumpster	+	1.0 fc	1.5 fc	0.5 fc	3.0:1	2.0:1	0.7:1				
Entry	+	0.0 fc	0.3 fc	0.0 fc	N/A	N/A	0.0:1				
Front Lawn	+	0.0 fc	0.2 fc	0.0 fc	N/A	N/A	0.0:1				
Parking Lot	+	1.4 fc	2.4 fc	0.2 fc	12.0:1	7.0:1	0.6:1				
Pine Street	+	0.0 fc	0.1 fc	0.0 fc	N/A	N/A	0.0:1				
Side Lawn	+	0.0 fc	0.3 fc	0.0 fc	N/A	N/A	0.0:1				
Sidewalk	+	0.0 fc	0.2 fc	0.0 fc	N/A	N/A	0.0:1				
Sidewalk #2	+	0.0 fc	0.2 fc	0.0 fc	N/A	N/A	0.0:1				

Designer
AmyRiley
Date
3/4/2015
Scale
Not to Scale
Drawing No.



D-Series Size 0


.ED Area Luminaire






Specifications

EPA: 26" Length: (66.0 cm) 13" Width: (33.0 cm) Height: (17.8 cm) Weight 16 lbs (max):





MAR 1 0 2015

DEPARTMENT OF PLANNING & ZOMINIC

His the Tub key or mouse over the page to see all interactive elements.

Introduction

The modern styling of the D-Series is striking yet unobtrusive - making a bold, progressive statement even as it blends seamlessly with its environment.


The D-Series distills the benefits of the latest in LED technology into a high performance, high efficacy,

long-life luminaire. The outstanding photometric performance results in sites with excellent uniformity, greater pole spacing and lower power density. It is ideal for replacing up to 400W metal. halide with typical energy savings of 65% and expected service life of over 100,000 hours.

Ordering Information

EXAMPLE: DSX0 LED 40C 1000 40K T3M MVOLT SPA DDRYD

DSX0 LED																
Series	Mas	Drive o	unent	Color ten	perature	Distribution		Voltage	e Mounting		Control options		Other options		Finish trequired)	
DSXO LED	Forward optics 20C 20 LEDs (one engine) 40C 40 LEDs (two engines) Rotated optics¹ 30C 30 LEDs (one engine)	530 700 1000	530 mA 700 mA 1000 mA (1 A) ²	30K 40K 50K AMBPC	3000 K 80 CRI min.) 4000 K (70 CRI min.) 5000 K (70 CRI) Amber phosphor converted '	T1S T2S T2M T3S T3M T4M TFTM T5VS	Type'l short Type II short Type II medium Type III short Type III short Type III medium Type IV medium Forward throw medium Type V very short Type V short Type V short Type V medium Type V wide	MVOLT ⁴ 120 ⁴ 208 ⁴ 240 ⁴ 277 ⁴ 347 ⁵ 480 ⁵	SPA RPA WBA SPUMBA RPUMBA	included Square pole mounting Round pole mounting Wall bracket Square pole universal mounting adaptor 6 Round pole universal mounting adaptor 6 separately 7 Mast arm mounting bracket adap- tor (specify finish)	Shipp PER DMG DCR PIR PIRH BL30 BL50	ned installed NEMA twist-lock receptacle only (no controls) * 0-10V dimming driver (no controls) * Dimmable and controllable via ROAM* (no controls) 10 Motion sensor, 8-15' mounting height 11 Motion sensor, 15-30' mounting height 11 Bi-level switched dimming, 30% 12 Bi-level switched dimming, 50% 12	Shipp insta HS SF DF L90 R90		DDBXD DBLXD DNAXD DWHXD DDBTXD DBLBXD DNATXD DWHGXD	Dark bronze Black Natural aluminu White Textured dark bronze Textured black Textured natural aluminu Textured white



DLL127F 1.5 JU DIT 347F 1 5 CUI III DLL480F 1.5 CUL JU SCU DSXOHS 20CU DSXOHS 30C II DSXOHS 40CU DSXODDL U

PUMBA DDBXD U*

KMA8 DDBXD U

Photocell - SSL twist-lock (120-277V) 15 Photocell - SSL twist-lock (347V) 15 Photocell - SSL twist-lock (480V) 15 Shorting cap 11

House-side shield for 201 FD unit 13 House-side shield for 301 FD unit 13 House-side shield for 40 LFD unit 13 Diffused drop lens (polycarbonate) 12 Square and round pole universal mounting bracket adaptor (specify finish) Mast arm mounting bracket adaptor

introl options, visit DIL and SOAM online

DSXO shares a unique drilling pattern with the AERIS™ family. Specify this drilling pattern when specifying poles, per the table below.

DM19AS Single unit DM29AS 2 at 90° * DM28AS 2 at 180° DM39AS 3 at 90° * 4 at 90° * 3 at 120° ** DM32AS

Example: SSA 20 4C DM19AS DDBXD

Visit Lithonia Lighting's FOLES CENTRAL to see our wide selection of poles, accessories and educations

tools.

*Round pole top must be 3.25**0.D. minimum *For round pole mounting (RPA) only.

Tenon Mounting Slipfitter **

AST20-190 AST20-280 AST20-290 AST20-320 AST20-390 AST20-490 AST25-190 AST25-280 AST25-290 AST25-320 AST25-390 AST25-490 AST35-190 AST35-280 AST35-290 AST35-320 AST35-390 AST35-490

- NOTES

- TES
 30 LEDs (30C option) and rotated options (L90 or R90) only available together.
 1000mA is not available with AMBPC.
 AMBPC only available with 530mA or 700mA.
 MVOLT driver operates on any line voltage from 120-277V (50/60 Hz). Specify 120,
 208, 240 or 277 options only when ordering with fusing (SF, DF options).
 Not available with single-board, 530 mA product (20C 530 or 30C 530). Not
 available with DCR, BL30, or BL50.
 Available as a separate combination accessory: PUMBA (finish) U; 1.5 G vibration
 load rating per ANCI C136.31.
 Must be ordered as a separate accessory: see Accessories information. For use

- Must be ordered as a separate accessory; see Accessories information. For use with 2-3/8" mast arm (not included).
- Photocell ordered and shipped as a separate line item from Acuity Brands Controls. See accessories.

 DMG option for 347v or 480v requires 1000mA.
- DMG option for 341 or 4607 requires 1000ms.

 Specifies a ROAM® enabled luminaire with 0-10V dimming capability; PER option required. Not available with 347 or 480V. Additional hardware and services required for ROAM® deployment; must be purchased separately. Call 1-800-442-6745 or email: sales@roamservices.net. N/A BL30, BL50, PIR, or PIRI. PIR specifies the SensorSwitch SSGR-10-ODP control; PRH specifies the SensorSwitch SSGR-10-ODP control; PRH specifies the SensorSwitch SSGR-10-ODP control; PRH specifies the SensorSwitch SSGR-10-ODP control see Motion Sensor Guide for details. Dimming driver standard. Not available with DCR.
- Requires an additional switched circuit. Dimming driver standard. MVOLT only. Not available with DCR.
- Also available as a separate accessory; see Accessories information. HS and DDL are not available together.
- Single fuse (SF) requires 120, 277 or 347 voltage option. Double fuse (DF) requires 208, 240 or 480 voltage option.
- Requires luminaire to be specified with PER option. Ordered and shipped as a separate line item from Acuity Brands Controls.



Performance Data

Lumen Ambient Temperature (LAT) Multipliers

Use these factors to determine relative lumen output for average ambient temperatures from 0-40 °C (32-104 °F).

Ami	pient	Lumen Multiplier
0°C	32°F	1.02
10°C	50°F	1.01
20°C	68°F	1.00
25°C	77°F	1.00
30°C	86°F	1.00
40°C	104°F	0.99

Projected LED Lumen Maintenance

Data references the extrapolated performance projections for the platforms noted in a 25°C ambient, based on 10,000 hours of LED testing (tested per IESNA LM-80-08 and projected per IESNA TM-21-11).

To calculate LLF, use the lumen maintenance factor that corresponds to the desired number of operating hours below. For other lumen maintenance values, contact factory.

Operating Hours	0	25,000	50,000	100,000					
	DSX0 LED 20C 1000								
	1	0.97	0.97 0.94						
Lumen Maintenance		D5X0 LED 40C 1000							
Factor	1	0.94	0.90	0.84					
		DSX0 LED	40C 700						
	1	0.99	0.98	0.96					


Electrical Load


		System Walts	Current (A)							
	Drive Current (mA)		120	208	240	277	347	480		
530 20C 700 1000	530	35	0.34	0.22	0.21	0.20				
	45	0.47	0.28	0.24	0.22	0.18	0.14			
	72	0.76	0.45	0.39	0.36	0.36	0.26			
	530	52	0.51	0.31	0.28	0.25	-	-		
	700	70	0.72	0.43	0.37	0.34	0.25	0.19		
	1000	104 1.11 0.64 0.56	0.56	0.49	0.47	0.34				
40C	530	68	0.71	0.41	0.36	0.33	0.25	0.19		
	700	91	0.94	0.55	0.48	0.42	0.33	0.24		
	1000	138	1.45	0.84	0.73	0.64	0.69	0.50		


Photometric Diagrams


To see complete photometric reports or download .ies files for this product, visit Lithonia Lighting's D-Series Area homepage.

Isofootcandle plots for the DSX0 LED 40C 1000 40K. Distances are in units of mounting height (20').









FEATURES & SPECIFICATIONS

INTENDED USE

The sleek design of the D-Series Size 0 reflects the embedded high performance LED technology. It is ideal for many commercial and municipal applications, such as parking lots, plazas, campuses, and streetscapes.

CONSTRUCTION

Single-piece die-cast aluminum housing has integral heat sink fins to optimize thermal management through conductive and convective cooling. Modular design allows for ease of maintenance and future light engine upgrades. The LED driver is mounted in direct contact with the casting to promote low operating temperature and long life. Housing is completely sealed against moisture and environmental contaminants (IP65). Low EPA (0.8 ft²) for optimized pole wind loading.

FINISH

Exterior parts are protected by a zinc-infused Super Durable TGIC thermoset powder coat finish that provides superior resistance to corrosion and weathering. A tightly controlled multi-stage process ensures a minimum 3 mils thickness for a finish that can withstand extreme climate changes without cracking or peeling. Available in both textured and non-textured finishes.

OPTICS

Precision-molded proprietary acrylic lenses are engineered for superior area lighting distribution, uniformity, and pole spacing. Light engines are available in standard 4000 K (70 minimum CRI) or optional 3000 K (80 minimum CRI) or 5000 K (70 CRI) configurations. The D-Series Size 0 has zero uplight and qualifies as a Nighttime Friendly™ product, meaning it is consistent with the LEED³ and Green Globes™ criteria for eliminating wasteful uplight.

ELECTRICAL

Light engine(s) configurations consist of high-efficacy LEDs mounted to metal-core circuit boards to maximize heat dissipation and promote long life (up to L96/100,000 hours at 25°C). Class 1 electronic drivers are designed to have a power factor >90%, THD <20%, and an expected life of

100,000 hours with <1% failure rate. Easily serviceable 10kV or 6kV surge protection device meets a minimum Category C Low operation (per ANSI/IEEE C62.41.2).

INSTALLATION

Included mounting block and integral arm facilitate quick and easy installation. Stainless steel bolts fasten the mounting block securely to poles and walls, enabling the D-Series Size 0 to withstand up to a 3.0 G vibration load rating per ANSI C136.31. The D-Series Size 0 utilizes the AERISTM series pole drilling pattern. Optional terminal block, tool-less entry, and NEMA photocontrol receptacle are also available.

LISTINGS

UL Listed for wet locations. Light engines are IP66 rated; luminaire is IP65 rated. Rated for -40°C minimum ambient. U.S. Patent No. D672,492 S. International patent pending.


DesignLights Consortium@ (DLC) qualified product. Not all versions of this product may be DLC qualified. Please check the DLC Qualified Products List at www.designlights.org to confirm which versions are qualified.

WARRANTY


Five-year limited warranty. Full warranty terms located at: www.ecuitybrands.com/CustomerResources/Terms_and_conditions.asp.:

Note: Actual performance may differ as a result of end-user environment and application. All values are design or typical values, measured under laboratory conditions at 25 $^{\circ}$ C. Specifications subject to change without notice.










Foundation Plan

JRMA | DESIGN STUDIO architects + development + interiors





A201

COA LEVEL II




DEPARTMENT OF PLANNING & ZONING



2nd Floor Level 161'-0"



DEPARTMENT OF PLANNING & ZONING




3rd Floor Level 171'-3"

2015

SCALE 3/32" = 1'-0"






Roof Plan | Option A | No Screening

JRMA | DESIGN STUDIO architects + development + interiors





Roof Plan | Option B | Screening

JRMA | DESIGN STUDIO architects + development + interiors

SCALE 3/32" = 1'-0"




RENDERING| PINE STREET

SCALE 3/32" = 1'-0"























A402






NORTH ELEVATION


SCALE 3/32" = 1'-0"





A450

Wall Panel - DW-2



- FEATURES

 DW panels have no exposed fasteners for a clean, continuous aesthetic offered in stucco embossed or smooth finishes.
- · Architectural flush panel was designed for usage in vertical or
- Easy to install tongue-and-groove engagement system.
 The DW panels features a common lock-joint design that allows for creative mix and match of panels.

SEAM HEIGHT / PANEL DEPTH • 1 1/2" [38.1mm]

PANEL COVER WIDTH

- METAL OPTIONS

 18 [1.19mm], 20 [.91mm], 22 [.76mm], 24 [.60mm], & 26 [.48mm] gauge G90 galvanized steel, Galvalume®

 .032* [.81mm], .040* [1mm] & .050* [1.27mm] aluminum
- 20 [.91mm], 22 [.76mm] & 24 [.60mm] gauge stainless steel
- . 16 oz. or 20 oz. Natural Copper Other metal options are available

SURFACE OPTIONS

- Embossed

- Symphony™ Silicone Polyester
 Symphony™ Kynar500® (PVDF)
 Acrylic Coated Galvalume®


- Galvalux™ Acrylic Coated G90 Galvanized

PANEL LENGTHS

• 5ft. [1.52m] to 45 ft. [13.71 m] standard

Shorter & longer lengths available - contact Steelogic.

ASSEMBLY DETAIL:



Subject to change without notice. Copyright 2013 © Steelogic



www.steelogic.com

Questions? Contact our Technical Department at: ptech@steelogic.com

DW panels have no exposed fasteners for a clean, continuous

12" (304.8 mm)

- aesthetic offered in stucco embossed or smooth finishes. Architectural flush panel was designed for usage in vertical or horizontal applications on walls, fascia's, or soffits.
- Easy to install tongue-and-groove engagement system.
- The DW panels features a common lock-joint design that allows for creative mix and match of panels.

SEAM HEIGHT / PANEL DEPTH

• 1 1/2" [38.1mm]

FEATURES

PANEL COVER WIDTH • 12" [304.8mm]

1-888-758-9758

- METAL OPTIONS

 18 [1.19mm], 20 [.91mm], 22 [.76mm], 24 [.60mm], & 26 [.48mm] gauge G90 galvanized steel, Galvalume®
- .032" [.81mm], .040" [1mm] & .050" [1.27mm] aluminum
- 20 [.91mm], 22 [.76mm] & 24 [.60mm] gauge stainless steel
- 16 oz. or 20 oz. Natural Copper Other metal options are available

SURFACE OPTIONS


Embossed

- Symphony™ Silicone Polyester
- Symphony™ Kynar500® (PVDF)
 Acrylic Coated Galvalume®
- Galvalux™ Acrylic Coated G90 Galvanized

PANEL LENGTHS

• 5ft. [1.52m] to 45 ft. [13.71 m] standard Shorter & longer lengths available - contact Steelogic

ASSEMBLY DETAIL:



Subject to change without notice. Copyright 2013 © Steelogic



www.steelogic.com Questions? Contact our Technical Department at: ptech@steelogic.com

METAL PANEL DETAILS

SCALE 3/32" = 1'-0"